



Product Service

CERTIFICATE

No. B 019303 0024 Rev. 01

Holder of Certificate: **RAFI GmbH & Co.KG**

Ravensburger Str. 128-134
88276 Berg / Ravensburg
GERMANY

Certification Mark:



Product: **Electrical controlling equipment
(Emergency switch off)**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the Testing, Certification, Validation and Verification Regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 713387264

Valid until: 2030-11-18

Date, 2025-11-21

(Benedikt Pulver)

CERTIFICATE

No. B 019303 0024 Rev. 01

Model(s): RAMO 22E, RAMO 30E

Parameters:

Utilization category:	AC-15 (35V)
	DC-13 (35V)
Nominal current (I_n)	0.1A
Insulation voltage (U_i)	250V
Rated impulse withstand voltage (U_{imp})	2500V
Conditional short-circuit current (I_{cc})	1000A
Operating temperature (T_{op})	-40°C to 85°C

Conditions of Acceptability

When installing all requirements of mentioned test specification(s) and conditions of acceptability must be fulfilled.

Tested according to: EN 60947-1:2007/A2:2014
EN 60947-5-1:2017
EN 60947-5-5:1997/A2:2017
EN ISO 13850:2015