



中国国家强制性产品认证证书

证书编号: 2025010305766157

认证委托人名称及地址

RAFI GmbH & Co. KG
Ravensburgerstr. 128 - 134, D-88276 Berg, Germany

生产者名称及地址

RAFI GmbH & Co. KG
Ravensburgerstr. 128 - 134, D-88276 Berg, Germany

生产企业名称及地址

Georg Schlegel GmbH & Co. KG
Kapellenweg 4, 88525 Dürmentingen, Germany

产品名称和系列、型号、规格

控制开关

LUMOTAST 22; Ui: 250V; Uimp: 2.5kV; AC-15: Ue/Ie: AC250V/1.5A; DC-13:
Ue/Ie: DC250V/0.27A; Ith: 5A; 安装孔径: $\Phi 22$ mm; 防护等级: IP65(操作面). 型号解释
详见附页

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024)的要求, 特发此证。

发证日期: 2025 年 04 月 01 日 有效期至: 2030 年 03 月 31 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:



谢肇煦

中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2025010305766157

NAME AND ADDRESS OF THE APPLICANT

RAFI GmbH & Co.KG
Ravensburgerstr. 128 - 134, D-88276 Berg , Germany

NAME AND ADDRESS OF THE MANUFACTURER

RAFI GmbH & Co.KG
Ravensburgerstr. 128 - 134, D-88276 Berg , Germany

NAME AND LOCATION OF THE FACTORY

Georg Schlegel GmbH & Co. KG
Kapellenweg 4, 88525 Dürmentingen, Germany

PRODUCT NAME,MODEL AND SPECIFICATION

Control Switch
LUMOTAST 22;Ui: 250V; Uimp : 2.5kV ; AC-15: Ue/Ie:AC250V/1.5A; DC-13:
Ue/Ie:DC250V/0.27A; Ith:5A; Aperture:Φ22mm.Levels of protection :IP65(Working face);See the
Appendix

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Apr.01,2025

Valid until: Mar.31,2030

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





中国国家强制性产品认证证书

证书编号: 2025010305766157

证书附页: 第 1 页 共 1 页

3.3 型号的解释:

LUMOTAST means the product family 表示产品的系列
22 means the mounting hole diameter 表示安装的孔径
1.15.105. means the basic designation for LUMOTAST 22 表示 LUMOTAST22 系列的料号开头
.0xx describes the different types/variants (details see below)描述不同的类型 (详细如下)
/0000 no meaning is attached for this four digits 没有任何意义

Different types see nomenclature 不同型号命名

LUMOTAST 22 Emergency stop switch 2 NC	1.15.105.001/0000
LUMOTAST 22 Emergency stop switch 2 NC illuminable	1.15.105.011/0000
LUMOTAST 22 Emergency stop switch 2 NC + 1 NO	1.15.105.021/0000
LUMOTAST 22 Emergency stop switch 1 NC + 1 NO	1.15.105.031/0000
LUMOTAST 22 急停开关 2 NC	1.15.105.001/0000
LUMOTAST 22 急停开关 2 NC 可发光	1.15.105.011/0000
LUMOTAST 22 急停开关 2 NC + 1 NO	1.15.105.021/0000
LUMOTAST 22 急停开关 1 NC + 1 NO	1.15.105.031/0000
LUMOTAST 22 Emergency stop switch 2 NC	1.15.105-002/0000
LUMOTAST 22 Emergency stop switch 2 NC illuminable	1.15.105-012/0000
LUMOTAST 22 Emergency stop switch 2 NC + 1 NO	1.15.105-022/0000
LUMOTAST 22 Emergency stop switch 1 NC + 1 NO	1.15.105-032/0000
LUMOTAST 22 急停开关 2 NC	1.15.105.002/0000
LUMOTAST 22 急停开关 2 NC 可发光	1.15.105.012/0000
LUMOTAST 22 急停开关 2 NC + 1 NO	1.15.105.022/0000
LUMOTAST 22 急停开关 1 NC + 1 NO	1.15.105.032/0000

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司